

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

**0905-CPR-250287**

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

**Product(s):** Series of Power Supply Equipment  
(refer to attached appendix for details and conditions)

**Placed on the market under the name or trade mark of:** Dycon Power Solutions Ltd.  
Unit A, Cwm Cynon Business Park, Mountain Ash  
CF45 4ER Wales, United Kingdom

**and produced in the manufacturing plant(s):** Dycon Power Solutions Ltd. (SG-15023)  
Unit A, Cwm Cynon Business Park, Mountain Ash  
CF45 4ER Wales, United Kingdom

**Intended use:** Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

**EN 54-4:1997+A1:2002+A2:2006**

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued on **2025-05-19** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

**Notified Body**  
**0905**

**Certification Manager:** Dipl.-Ing. Roland Heine

**Date Issue:** 2025-05-19

**Issue:** 1

**Signature:**

122326

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-250287

## APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-250287

The details and conditions of use for the Series of Power Supply Equipment, placed on the market under the name or trade mark of:

**Dycon Power Solutions Ltd.**

**Unit A, Cwm Cynon Business Park, Mountain Ash  
CF45 4ER Wales, United Kingdom**

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

**Products compliant with EN 54-4:1997+A1:2002+A2:2006**

Model	Manufacturing Location	Description
D2431-7	SG-15023	1.5A Power Supply Equipment with 7Ah Batteries in Medium Standalone Enclosure
D2433-7	SG-15023	3A Power Supply Equipment with 7Ah Batteries in Medium Standalone Enclosure
D2433-17	SG-15023	3A Power Supply Equipment with 17Ah Batteries in Large Standalone Enclosure
D2435-17	SG-15023	5A Power Supply Equipment with 17Ah Batteries in Large Standalone Enclosure

### Conditions of use:

Suitable for indoor applications only.

### General Notes:

1. Evaluated under Intertek project number 101464530, 102351153 and 106099615
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.