

## Product Withdrawal Notice

<b>Product Withdrawal Notice No.</b>	<b>PWN0002</b>
<b>Product No.</b>	<b>D2475-A/B/C/P</b>
<b>Description</b>	<b>D2475</b> , 24VDC 5A PSUs with remote switching, fault output but without battery charging capability
<b>Final Withdrawal Date</b>	<b>1<sup>st</sup> January 2016</b>
<b>Reason for Withdrawal</b>	Component obsolescence and increasing demand for battery charging capability
<b>Replacement Options</b>	<i><b>D2445-B/C</b> 24VDC 5A PSU with volt-free outputs and LED displays for PSU fault, battery fault, AC power status . On/Off power switching control input with pull-up, compatible with voltage-free contacts, Jumper for selecting inverted or normal power switching operation. Status LED display indicating normal/standby operation and On/Off switching status, power supply internal monitoring, Over-voltage output protection, inductive and capacitive load switching surge protection and snubbing, Intelligent electronic fuse output protection with automatic reset, constant-current battery charging.</i>
<b>Further Information</b>	<b>Contact;</b> e-mail <a href="mailto:sales@dyconpower.com">sales@dyconpower.com</a> , Telephone <b>+44 (0)14443 471900</b> Website: <a href="http://www.dyconpower.com">www.dyconpower.com</a>